

ENTERED 10/20/2011 SAK

CASE NUMBER 20040237958

COMMENTS: THE VIOLATION IS BASED ON THE CAN DOES NOT MEET THE CRITERIA FOR "UNSAFE" ILLUMINATION

CASENUM A2010002008-X (EXPIRED PERMITS)

8-1 FAILURE TO OBTAIN REQUIRED INSPECTION FLORIDA BUILDING CODE SECTION 105.6

COMMENTS: NO PERMIT FOUND FOR VIOLATION CORRECTION AND LETTER OF ILLUMINATION COMPLIANCE WITH 8C-3 OF THE MDCC FROM P.E. WAS NOT RECEIVED.

CASENUM A2010002008-X (EXPIRED PERMITS)

8-1 FAILURE TO OBTAIN REQUIRED INSPECTION FLORIDA BUILDING CODE SECTION 105

SHOW ALL ELECTRICAL VIOLATIONS REFERENCED IN ENF CASE ON ELECTRICAL PLANS TO BE CORRECTED

2.0 1.7 1.9 4.2 3.9 4.2

TYPE	DESCRIPTION	MANUFACTURER	CATALOG NUMBER	LAMPS QTY	TYP	VOLTS	MOUNTING	REMARKS
A	6" DOWNLIGHT	HALO	H71CT	1	75W par20	120	RECESSED	TRIM & ACCESSORIES BY OWNER

2.0 1.7 1.9 4.2 3.9 4.2


TYPE	DESCRIPTION	MANUFACTURER	CATALOG NUMBER	LAMPS QTY	TYP	VOLTS	MOUNTING	REMARKS
A	6" DOWNLIGHT	HALO	H71CT	1	75W par20	120	RECESSED	TRIM & ACCESSORIES BY OWNER

ELEC MODE, BY OWNER, LENGTH PER FIELD CONDITIONS N IN MEET OF CRITERIA, DISAPPROVED OWNER'S REQUEST.	Approved As Noted Disapproved
--	----------------------------------

N: NEW
EX: EXISTING



SCALE: 1/4"=1'-0"



DESIGN TEAM:



16500 N.W. 91st ct.
Miami Lakes, Florida 33018
Cel: 305-401-4395

PROJECT:

OWNER:
USHA RAMCHANDANI
8617 SW 133 PL
MIAMI, FL 33183

PROJECT:

**INTERIOR BUILD-OUT:
LUGGAGE WORLD #1050
DADELAND MALL
7535 SW 88 STREET
MIAMI, FL 33156**

MANAGEMENT:

SHEET TITLE:

**DEMOLITION
AND PROPOSED
ELECTRICAL
FLOOR PLAN**

SHEET No:

E-2